Radiological Protection Aspects of the Generic Design Assessment of Potential New Nuclear Reactors in the UK



Grant InghamInspector,
Office for Nuclear Regulation




IRPA13 Glasgow

May 2012



Approach (1)

- Four Step process
- Assessment criteria:
 - Relevant UK legislation (e.g. IRR99)
 - National and international standards
 - HSE Safety Assessment Principles (SAPs)
- Publication of reports http://www.hse.gov.uk/newreactors/





Approach (2)

- Challenges:
 - Significant amount of documentation
 - Wide scope of topics to be assessed
 - Designs from countries with differing regulatory frameworks
 - Operating procedures not finalised
 - Differences in language/metrology
- Sampling approach
- Consistent approach
- Technical Support Contractors (TSCs)



General Outcomes

- We were broadly satisfied with the claims, arguments and evidence within the Requesting Parties' safety cases and supporting documentation for radiological protection.
 - Worker doses (routine and accident) had been reduced so far as is reasonably practicable
 - Predicted doses to members of the public are very low
- We considered that from a radiological protection view point, the designs are suitable for construction in the UK
 - Subject to the satisfactory progression and resolution of one GDA Issue for each design
 - There are a number of Assessment Findings that will require further analysis by future licensees during the site specific phase



GDA Issues and Assessment Findings

Two mechanisms for capturing ongoing matters of concern:

GDA Issues

 Matters of particular significance that will require resolution before ONR would agree to the commencement of nuclear island safety related construction of the reactor design in the UK

Assessment Findings

- Matters where the lack of detailed information limited the extent of ONR's assessment
- Require further analysis by future licensees during the site specific phase



Topics Covered in Step 4

Assessment areas relevant to normal operation

- Radiation sources.
- Designated areas (radiological classification of areas / radiological zoning).
- Shielding.
- Contaminated Areas.
- Ventilation.
- Radiological instrumentation.
- Decontamination.
- Optimisation for work activities (including fuel route).
- Waste handling and decommissioning.
- Public exposure from direct shine (direct radiation originating from within the site boundary).

Assessment areas relevant to accident conditions

- Criticality control in the spent fuel pool.
- Persons on-site.
- Intervention personnel.



Points of Interest by Topic (1)

- Radiation sources
 - Adequate
 - Assessment Findings
- Radiological zoning and shielding
 - AP1000 Adequate. Assessment Findings
 - EPR GDA Issue zoning and bulk shielding
- Contaminated areas
 - Adequate
 - Assessment findings



Points of Interest by Topic (2)

- Optimisation for work activities
 - Adequate. Doses ALARP
 - Assessment Findings
- Public exposure
 - Adequate. Public doses very low (<30 micro sieverts per year)
- Waste handling and Decommissioning
 - Adequate approach
 - Assessment findings



Points of Interest by Topic (3)

- Accident conditions
 - EPR
 - Adequate
 - Assessment Findings
 - AP1000
 - GDA Issue Criticality control of the Spent Fuel Pool



Summary

- From a radiological protection view point, the designs are suitable for construction in the UK
 - subject to satisfactory resolution of GDA Issues
- One GDA Issue identified for each reactor
- Assessment Findings:
 - 20 for EPR, 15 for AP1000
- Questions?

